

Mark Woolbright, President
St. Louis Retaining Wall Co.
February 13, 1995
Page 2

5. Submit four sets of cross-section details of wall. This must show leveling pads, wall height, slope of wall and slope of backfill.
6. Applicant must indicate whether he is using the Standard or Mega Hercules Blocks.

If you have any questions, please feel free to call me.

Sincerely,



Siti Kirkpatrick, P.E., 889-3733
Building Code Review Section
Division of Building Permits

SK:am